

HIGGINS & HEWINS

Media Sample Analysis Report

Customer Name: Water Company Plc

Contact Person: John Smith

Telephone Number: 01234 567891

Location: England WwTW

Report Date: 01/09/2009

	Bed 1	Bed 2	Bed 3
Unit Type	DBS 2P/1.8/2	DBS 2P/1.8/2	DBS 2P/1.8/2
Machine No.	P927	P927	P927
Sample Ident. No	S 5008	S 5009	S 5010
Media Installed	01/03/2005	01/03/2005	01/03/2005
Sample Date	31/07/2009	31/07/2009	31/07/2009
Period in Service	Approx 1600 Days	Approx 1600 Days	Approx 1600 Days
Media Type	Jasorb G-15	Jacarb L-65	Jasorb P-8
Moisture	16.73%	22.19%	15.04%
Life Remaining	42%	17%	13.5%
Replacement Date	May 2011	May 2010	Feb 2010

Comments:

Jasorb G-15 – The analysis shows that this media has 42% life remaining, giving an approx replacement date of May 2011. However with the media in Beds 2 and 3 requiring replacement soon we would advise to replace this media at the same time to reduce costs.

Jacarb L-65 – The analysis shows that this media has 17% life remaining, giving an approx replacement date of May 2010.

Jasorb P-8 – The analysis shows that this media has 13.5% life remaining, giving an approx replacement date of Feb 2010.